

Corrigendum 01 (Pre-Bid Meeting Clarifications)



Date:31/03/2022

Tender Title: AMC for Operation and Maintenance of Water Supply and STP @HMT Township,
Jalahalli, Bangalore - 560013

NIT Ref: HMTL/ABD/AMC-WS/2022-23 Dated: 17-03-2022

Pre Bid Scheduled on: 24.03.2022 @ 11AM

Department Name: HMT Limited, Auxiliary Business Division, Jalahalli, Bangalore - 560013.

Sl No.	Tender Clause	Bidder Query	Clarification by M/s HMT Limited
01	Tender Document Page No. 13, Point No.10, Testing Meters/Equipment should be provided by the contractor with valid calibration certificate.	Give the List of Testing Equipment	1. pH, TDS, Conductivity, Turbidity and Temperature along with necessary testing beakers/apparatus testing digital meters which are in working condition are to provided. 2. Two sets, one set for Water Supply and One set for STP.
02	Tender Document page no. 13, point No. 5 The Sludge drying beds shall be loaded as per the schedule or as directed. The dried cakes shall be removed after drying and neatly stacked as per norms of KSPCB norms	1. Our concern is about operation of STP. 2. We need extra manpower for loading of sludge for which HMT has to agree.	1. Loading of dry beds from Digester tank to Dry beds. Leaving for drying is part of Operation of STP. 2. No extra man days will be considered. However selling of Manure and Tender Coconuts will be considering including man power for loading/plucking. 3. Ultimate responsible of contractor is to maintain the complete operations of STP.
03	Tender Document Page No.3 Technical Bid Shall be opened on 09.03.2022	Typing Mistake Technical Bid Date should be 09.04.2022	Kindly note: The date of Technical bid opening is on 09.04.2022 (Saturday) at 02:30PM @ Office of Electrical and Water Supply Department.

Note: All other terms and conditions remains same as per the above mentioned NIT.

Sd/-
Deputy Engineer (WS &E)